



Series PFC2000-4000 Boilers Approved Venting Materials Specification Supplement to Installation Manual

The information supplements the venting section in the Boiler Installation, Operation and Maintenance Manual (PFC8201 R0).

PFC-2000/4000 Approved Venting Materials	
Air Intake	Vent
PVC ¹	CPVC ¹
Galvanized Steel	Polypropylene
	Stainless Steel
<p>Vent installations shall be in accordance with the current <i>National Fuel Gas Code</i>, ANSI Z223.1/NFPA 54 or the <i>Natural Gas and Propane Installation Code</i>, CSA B149.1, or applicable provisions of the local building codes.</p> <p>Covering non-metallic vent pipe and fittings with thermal insulation shall be prohibited.</p> <p>¹ Use of cellular core PVC (ASTM F891), cellular core CPVC, or Radel® (polyphenylsulfone) in venting systems shall be prohibited.</p>	